


RFP# 8525 Cosumnes River Blvd Rectifier Replacement Project Q&A's Revision No.3

1. Upon further review, we have determined that the SMUD meter number provided does not appear to be correct, as the indicated distance does not align with the rectifier location. Please see the attached images for reference. The Cosumnes rectifier is located approximately 5,000 feet east of Beach Lake Road and Interstate 5. The meter number provided appears to correspond to a different rectifier further down the roadway, located approximately 2,000 feet east of Beach Lake Road and Interstate 5. Also, we reached out to SMUD to get information on the meter number that was given and they couldn't even see that which is why we started looking deeper.



*Thank you for raising this and for checking with SMUD. The RFP states that the Contractor is responsible for coordinating with SMUD for electrical service to the new rectifier. After further internal review, we were not able to verify the meter number previously referenced, and we believe SMUD has deactivated the account that once served this location. Accordingly, the selected Contractor will need to work with SMUD to establish a new electrical service and meter for the Cosumnes River Blvd Rectifier site. This clarification is consistent with the utility-coordination responsibilities already described in the RFP and does not change the scope or evaluation criteria.*