

Questions and Responses

RFP#8501 Power Inn Pump Station N52 – Programmable Logic Controller Upgrades

Question #1

What is the purpose of the cell modem?

Response #1

The cell modem communicates with the EchoWater treatment plant.

Question #2

Is there a documented backup for the PLC?

Response #2

The backup programming exists but is not well documented.

Question #3

What is the purpose of the SCADA pack?

Response #3

The SCADA pack communicates with the SacSewer collections main office building.

Question #4

What is the downtime of the pump station?

Response #4

This station can be shut down indefinitely

Question #5

Will SacSewer allow a prevailing wage exemption?

Response #5

No.

Question #6

Will drawings be provided?

Response #6

Drawings can be provided if requested.

Question #7

What should be prepared for the pre-proposal presentation?

Response #7

The presentation should include the contractor's plan to complete the RFP.

Question #8

Does the contractor need to rewrite the new program for the PLC?

Response #8

The contractor will be responsible for any programming that does not convert from the old PLC to the new PLC.

Question #9

Does the replacement OIP need to be from Schneider Electric?

Response #9

No.

Question #10

Is the program for the hardware needing replacement in Fasttrack or is it now in Proworks 32?

Response #10

The program for the existing hardware is in Proworks32.

Question #11

Can you send the Proworks 32 file so the scope of the conversion is understood?

Response #11

The programming for the PLC and the HMI will be shared with the awarded contractor through a Non-Disclosure Agreement.

Question #12

Can you send the Panel Drawings?

Response #12

The panel drawings will be shared as attachments. The one-line panel diagram will be shared with the awarded contractor through a Non-Disclosure Agreement.