



**ADDENDUM NO. 2**

**SACRAMENTO AREA SEWER DISTRICT**

RFP#8501 Power Inn Pump Station N52 – Programmable Logic Controller Upgrade

The following change is amended in RFP#8501 Power Inn Pump Station N52 – Programmable Logic Controller Upgrade

Please change the following language from Special Provisions, page 9, section 6, Detailed Scope of Work, bullet point 2.

~~Furnish all necessary X80 I/O cards to reconnect to existing points, plus 20% spare capacity~~

Replace with:

Furnish all necessary X80 I/O cards to reconnect to existing points, plus 20% spare I/O cards

Thank you,

  
Tamblynn Stewart  
Sr. Contract Service Officer

May 15, 2025

Addendum No. 2

RFP#8501